



SELECT MAIN LINE/ CONDUCTOR 1	BURNDY WEJTAP CATALOG NUMBER																				
	SELECT JUMPER/ CONDUCTOR 2																				
	77 AAAC Ames (2 ACSR Eq) Item 603170 Dia 0.316	1/0 AAC Tree Quince Item 603218 Dia 0.368	123 AAAC Azusa (1/0 ACSR Eq) Item 603190 Dia 0.398	246 AAAC Alliance (4/0 ACSR Eq) Item 603211 Dia 0.563	336 ACSR Linnet (No Item #) Dia 0.720	394 AAAC Canton Item 603213 Dia 0.721	397 AAC Tree 150mil XLPE Item 603220 Dia 0.723	556 ACSR Dove (No Item #) Dia 0.927	652 AAAC Elgin Item 603652 Dia 0.927	795 ACSR Drake Item 603795 Dia 1.107	927 AAAC Greeley Item 603927 Dia 1.108	1272 AAC Narcissus Item 603956 Dia 1.300	2/0 Cu 7 strand HD Item 606210 Dia 0.414	4/0 Cu 7 strand HD Item 606211 Dia 0.522	2/0 Cu 19 strand SD Item 606208 Dia 0.419	4/0 Cu 7 strand HD Item 606211 Dia 0.522	4/0 Cu 19 strand SD Item 606209 Dia 0.528	250 Cu 37 strand SD Item 606212 Dia 0.573	500 Cu 37 strand SD Item 606215 Dia 0.814	600 Cu 61 strand SD Item 606216 Dia 0.891	750 Cu 61 strand SD THHN 600V Item 602220 Dia 0.998
77 AAAC Ames (2 ACSR Eq) Item 603170 Dia 0.316	WCB 10	WCB 10	WCB 10	WCY 50	WCY 50	WCY 50	WCY 50	WCY 67	WCY 67	WCY 83	WCY 83										
1/0 AAC Tree Quince Item 603218 Dia 0.368		WCB 14	WCB 14	WCY 51	WCY 52	WCY 52	WCY 52	WCY 66	WCY 66	WCY 81	WCY 81										
123 AAAC Azusa (1/0 ACSR Eq) Item 603190 Dia 0.398			WCB 14	WCY 51	WCY 52	WCY 52	WCY 52	WCY 65	WCY 65	WCY 81	WCY 81										
246 AAAC Alliance (4/0 ACSR Eq) Item 603211 Dia 0.563				WCY 52	WCY 64	WCY 64	WCY 64	WCY 81	WCY 81	WCY 97	WCY 97	WCY 114	WCY 51	WCY 51	WCY 52	WCY 52	WCY 52				
336 ACSR Linnet (No Item #) Dia 0.720					WCY 62	WCY 62	WCY 62	WCY 61	WCY 61	WCY 76	WCY 76	WCY 111	WCY 52	WCY 52	WCY 64	WCY 64	WCY 64				
394 AAAC Canton Item 603213 Dia 0.721						WCY 62	WCY 62	WCY 61	WCY 61	WCY 76	WCY 76	WCY 111	WCY 52	WCY 52	WCY 64	WCY 64	WCY 64				
397 AAC Tree 150mil XLPE Item 603220 Dia 0.723							WCY 62	WCY 61	WCY 61	WCY 76	WCY 76	WCY 111	WCY 52	WCY 52	WCY 64	WCY 64	WCY 64				
556 ACSR Dove (No Item #) Dia 0.927								WCY 60	WCY 60	WCY 73	WCY 73	WCY 109	WCY 65	WCY 65	WCY 81	WCY 81	WCY 81	WCY 61	WCY 60		
652 AAAC Elgin Item 603652 Dia 0.927									WCY 75	WCY 73	WCY 73	WCY 109	WCY 65	WCY 65	WCY 81	WCY 81	WCY 81	WCY 61	WCY 60		
795 ACSR Drake Item 603795 Dia 1.107										WCY 88	WCY 88	WCY 106	WCY 81	WCY 81	WCY 97	WCY 97	WCY 97	WCY 75	WCY 92	WCY 91	
927 AAAC Greeley Item 603927 Dia 1.108											WCY 88	WCY 106	WCY 81	WCY 81	WCY 97	WCY 97	WCY 97	WCY 75	WCY 92	WCY 91	
1272 AAC Narcissus Item 603956 Dia 1.300												WCY 103									
2/0 Cu 7 strand HD Item 606210 Dia 0.414													WCB 40 C20	WCB 40 C20							NOT APPLICABLE
4/0 Cu 7 strand HD Item 606211 Dia 0.522													WCB 40 C20	WCB 40 C20	WCB 250 C250	WCB 250 C250					





- Notes:
- See 12-150 Sheet 2 of 2 for corresponding Assembly Units.
 - BURNDY Catalog Number indicates Power Booster color (WCR = Red, WCB = Blue, WCY = Yellow).
 - Contact Standards for conductor combinations not listed in this table.
 - Catalog Numbers will have "PB" suffix to indicate that Power Booster cartridge is included in connector package.

STANDARDS		MATERIAL STANDARDS		REV	DATE	DESCRIPTION
 PUBLIC UTILITY DISTRICT NO. 1 Cowlitz County, Washington 961 12th Avenue Longview, Washington		OVERHEAD CONNECTORS		0	05/28/25	Initial release
		WEDGE TAP CONNECTORS		1	02/19/26	Updated 652-652, added 600mm Cu, resized SH 1, added A1's and code items for WCY92, 602180-4
Designed	Checked	Standards Approved	Std/Dwg No.			
D. Tuominen	M. Demos		12-150 (1 of 2)			

PREFERRED CONNECTOR			ALTERNATE CONNECTOR			NOTES
BURNDY WEJTAP CATALOG #	ASSEMBLY UNIT #	ITEM #	TE AMPACT CATALOG #	ASSEMBLY UNIT #	ITEM #	
WCB10	963079	800330	602283	963300	800335	
WCB14	963200	800350	600411	963301	800340	
WCY50	963201	800355	602000	963302	800345	
WCY51	963202	800365	600459	963303	800370	
WCY52	963203	800390	602002	963304	800385	
WCY60	963204	800550	1-602031-2	963305	800415	
WCY61	963205	800560	1-602031-3	963306	800395	
WCY62	963063	800570	602007	963307	800410	
WCY64	963064	800590				
WCY65	963062	800600	1-602031-7	963308	800425	
WCY66	963206	800610	1-602031-8	963309	800435	
WCY67	963065	800620	2-602031-0	963310	800445	
WCY73	963207	800625	602180-5	963311	800455	
WCY75	963208	800470	602121-4	963312	800465	
WCY76	963209	800475				
WCY81	963210	800485	1-602121-0	963313	800505	
WCY83	963211	800490	1-602121-2	963314	800525	
WCY88	963212	800500	602180-2	963315	800535	
WCY91	963213	800510	602180-5	963311	800455	
WCY92	963222	800515	602180-6	963325	800295	
WCY97	963214	800495	602121-7	963316	800555	
WCY103	963215	800545	602300	963317	800565	
WCY106	963216	800635	602300-2	963318	800575	
WCY109	963217	800640	602300-5	963319	800585	
WCY111	963218	800645	602300-8	963320	800595	
WCY114	963219	800650	1-602300-1	963321	800605	
WCB40C20	963220	800315	1-275187-5	963322	800285	2/0 Cu Str to 2/0 Cu Str
			275187-8	963323	800305	4/0 Cu Str to 2/0 Cu Str
WCB250C250	963221	800325	275187-6	963324	800290	

Notes:

1. Select BURNDY WEJTAP catalog number from chart on 12-150 Sheet 1 of 2.
2. Corresponding TE AMPACT connector may be used if needed. If the BURNDY Power Unit tool is used, select the BURNDY Power Booster shell based on the shell color indicated with the AMPACT connector.

 <p>PUBLIC UTILITY DISTRICT NO. 1 Cowlitz County, Washington 961 12th Avenue Longview, Washington</p>	STANDARDS		MATERIAL STANDARDS OVERHEAD CONNECTORS WEDGE TAP CONNECTORS		<table border="1"> <tr> <th>REV</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> <tr> <td>0</td> <td>05/28/25</td> <td>Initial release</td> </tr> <tr> <td>1</td> <td>02/19/26</td> <td>Updated 452-452, added 400mm Cu, revised SH 1, added ALJ's and code items for WCY92, 602180-6</td> </tr> </table>	REV	DATE	DESCRIPTION	0	05/28/25	Initial release	1	02/19/26	Updated 452-452, added 400mm Cu, revised SH 1, added ALJ's and code items for WCY92, 602180-6
	REV	DATE	DESCRIPTION											
0	05/28/25	Initial release												
1	02/19/26	Updated 452-452, added 400mm Cu, revised SH 1, added ALJ's and code items for WCY92, 602180-6												
<table border="1"> <tr> <td>Designed D. Tuominen</td> <td>Checked M. Demos</td> <td>Standards Approved </td> <td>Std/Dwg No. 12-150 (2 of 2)</td> </tr> </table>	Designed D. Tuominen	Checked M. Demos	Standards Approved 	Std/Dwg No. 12-150 (2 of 2)										
Designed D. Tuominen	Checked M. Demos	Standards Approved 	Std/Dwg No. 12-150 (2 of 2)											