



LONGITUDINAL (FACE) VIEW

TRANSVERSE (SIDE) VIEW

Notes:

1. Predrilled for use with code item 235137 Pole Eye Plates. Other configurations may require field drilling.
2. See the latest version of the Cowlitz PUD *Technical Specification for Wood Pole Equivalent Ductile Iron Utility Poles* for requirements regarding material, markings, and testing.
3. Any proposed deviation from this standard shall be clearly indicated by manufacturer at time of quotation.

STANDARDS		MATERIAL STANDARDS		REV	DATE	DESCRIPTION
 <p>PUBLIC UTILITY DISTRICT NO. 1 Cowlitz County, Washington 961 12th Avenue Longview, Washington</p>	<p>GUY POLES 35 FT CLASS 2, DUCTILE IRON</p>	0	11/06/25	Initial release		
		Designed	Checked	Standards Approved	Std/Dwg No.	
		D. Tuominen	C. Baierl D. Thomas			12-33