



ITEM	QTY	SUPPLIER	MATERIAL DESCRIPTION	NOTES
1	1	CUSTOMER	4" x 72" rigid steel conduit min, exposed portion painted yellow	A. Posts must be set as to not interfere with transformer doors opening. If this is not possible a removable post must be used. B. Call the PUD before digging post holes to locate any underground cables. C. For the removable bollard, coat the lower half of the 4" RSC in grease before installing. D. Bollards only required on road-facing sides of pad or where there is risk of collision with PUD equipment.
2	1	CUSTOMER	Plumbers 4" rounded cap	
3	1	CUSTOMER	5/8" x 8" machine bolt	
4	1	CUSTOMER	5/8" nut	
5	2	CUSTOMER	Round washer	
6	1	CUSTOMER	6" x 42" rigid steel conduit	

STANDARDS		CONSTRUCTION STANDARDS		REV	DATE	DESCRIPTION
		ELECTRICAL SERVICE REQUIREMENTS BOLLARD INSTALLATION		0	3/3/25	Initial release
Designed MJD/DPT		Checked DPT		Standards Approved 		Std/Dwg No. 7-86