



NOTES

- A. The customer is responsible for trenching to 2' away from existing box pad. Cowlitz PUD will trench and provide conduit for the final tie-in.
- B. The customer must install 2500 lb mule tape and provide at least 5' in excess.
- C. All conduit must be at a minimum trench depth of 36".
- D. All conduit and fittings must be schedule 40 gray electrical PVC.

 PUBLIC UTILITY DISTRICT NO. 1 Cowlitz County, Washington 961 12th Avenue Longview, Washington	CONSTRUCTION STANDARDS ELECTRICAL SERVICE REQUIREMENTS LATERAL TIE-IN		<table border="1"> <thead> <tr> <th>REV</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>06/21/22</td> <td>Initial release</td> </tr> <tr> <td>1</td> <td>5/12/25</td> <td>Renumber, 36" trench, remove hand dig portion, stub-ups</td> </tr> </tbody> </table>	REV	DATE	DESCRIPTION	0	06/21/22	Initial release	1	5/12/25	Renumber, 36" trench, remove hand dig portion, stub-ups
	REV	DATE	DESCRIPTION									
0	06/21/22	Initial release										
1	5/12/25	Renumber, 36" trench, remove hand dig portion, stub-ups										
Designed MJD/DPT	Checked DPT	Standards Approved 	Std/Dwg No. 7-90									