



Notes

- A. Meter must have a clear working space free of obstruction at least 3 feet wide, 3 feet deep, and 6 feet - 6 inches high (above final finished grade).
- B. Meter height must be between 5 and 6 feet from final grade.
- C. Meter base must have a minimum clearance of 10 inches from any protruding wall or other obstruction.
- D. Meter base must have a minimum clearance of 3 feet from any gas meter, door, or window with view of living space.

STANDARDS	CONSTRUCTION STANDARDS		REV	DATE	DESCRIPTION
			0	3/3/25	Draft for review
 <b>PUBLIC UTILITY DISTRICT NO. 1</b> Cowlitz County, Washington 961 12th Avenue Longview, Washington	<b>ELECTRICAL SERVICE REQUIREMENTS</b> <b>METER SOCKET LOCATION</b>				
			Designed	Checked	Standards Approved
	MJD	DPT			<b>8-12</b>