



NOTES

- A. Meter must have a clear working space at least 36" wide, 36" deep, and 78" high above the platform.
- B. Cowlitz PUD and the customer will determine when a platform is required and where it will be located. Contact Cowlitz PUD for variations in platform requirements. The platform must be approved by Cowlitz PUD prior to service connection.
- C. All lumber used to make the platform must be pressure-treated. The cost of construction shall be the responsibility of the customer. The customer must maintain the platform for future access and structural strength.
- D. The customer is responsible for permits or use of land associated with the meter access platform.
- E. The pole will be furnished and installed by the customer.
- F. The stair run will vary with the height of the platform, and the handrail stanchions will be equally spaced.
- G. **If a hazardous situation exists with a meter access platform, the customer will be notified. The customer will have 60 days to repair the safety or maintenance issue. Should repairs not be made after 60 days, the customer's service will be subject to termination.**

STANDARDS		CONSTRUCTION STANDARDS			REV	DATE	DESCRIPTION
 <p>PUBLIC UTILITY DISTRICT NO. 1 Cowlitz County, Washington 961 12th Avenue Longview, Washington</p>	<p>ELECTRICAL SERVICE REQUIREMENTS FLOOD ACCESS PLATFORM</p>			0	2/23/26	Initial release	
				Designed G. Reyes	Checked M. Demos	Standards Approved 	Std/Dwg No. 8-210