

200 Amp Approved Meter Bases

| Type | Usage | Amp rating | Jaws | Manufacturer | Model Number | Notes |
|--------------|----------------------|------------|--------------------|--------------------|---------------|---------------------------|
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | 124TB | 3" k/o, bypass, hub cover |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Milbank | U3514-XL | 3" k/o, bypass, hub cover |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Milbank | 124TB | 3" k/o, bypass, hub cover |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Eaton B-Line | UG204 | 3" knockout |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | MBE24L200BTS | 3" knockout |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | CMBE24L200BTS | 3" knockout |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Milbank | U4015-O | 3" knockout |
| Meter Main | Underground | 200 | 4 w/ 5th available | Milbank | U3584-O-200 | 3" knockout |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Milbank | U4518-XL-W | Hub cover |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Schneider Square D | CQRA200 | hub cover |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Schneider Square D | URTRS213B | hub cover |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Siemens Talon | UAT427-XG | Hub cover |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Siemens Talon | UAT427-XGSP | Hub cover, bypass |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Siemens Talon | UAT4270G | Hub opening |
| Meter Socket | Overhead | 200 | 4 w/ 5th available | Milbank | U4517-DL-M4 | Hub opening |
| Meter Main | Overhead | 200 | 4 w/ 5th available | Milbank | U3574-RL-200 | Hub opening |
| Meter Socket | Overhead | 200 | 4 w/ 5th available | Siemens Talon | UAT327-0G | Hub opening |
| Meter Socket | Overhead | 200 | 4 w/ 5th available | Eaton B-Line | 204MS68 | |
| Meter Socket | Overhead | 200 | 4 w/ 5th available | Eaton B-Line | 204MS68A | |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Eaton B-Line | U204 | |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Eaton B-Line | U204MS73 | |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Eaton B-Line | UG204MS82 | |

STANDARDS



PUBLIC UTILITY DISTRICT NO. 1
 Cowlitz County, Washington
 961 12th Avenue
 Longview, Washington

**CONSTRUCTION STANDARDS
 ELECTRICAL SERVICE REQUIREMENTS
 APPROVED METER BASES**

| REV | DATE | DESCRIPTION |
|-----|----------|-----------------|
| 0 | 06/09/25 | Initial release |
| | | |
| | | |

| | | |
|----------------------|------------------------|------------------------|
| Designed M. Demos | Checked D. Tuominen | Standards Approved |
|----------------------|------------------------|------------------------|

Std/Dwg No. **8-5 (1 of 3)**

200 Amp Approved Meter Bases (Continued)

| | | | | | | |
|--------------|----------------------|-----|--------------------|--------------------|---------------|--|
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | U204MS21 | |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | UNRRS213BEUSE | |
| Meter Socket | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | U204SSMS21 | |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | MBEB200BTS | |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Eaton B-Line | CMBEB200BTS | |
| Meter Main | Overhead/Underground | 200 | 4 w/ 5th available | Schneider Homeline | SC2040M200C | |
| Meter Main | Underground | 200 | 4 w/ 5th available | Schneider Homeline | SC816D200C | |
| Meter Socket | Overhead | 200 | 4 w/ 5th available | Eaton B-Line | 204.0000 | |
| Meter Socket | Underground | 200 | 4 w/ 5th available | Milbank | U4518-O-W | |

STANDARDS



PUBLIC UTILITY DISTRICT NO. 1
 Cowlitz County, Washington
 961 12th Avenue
 Longview, Washington

**CONSTRUCTION STANDARDS
 ELECTRICAL SERVICE REQUIREMENTS
 APPROVED METER BASES**

| REV | DATE | DESCRIPTION |
|-----|----------|-----------------|
| 0 | 06/09/25 | Initial release |
| | | |
| | | |

| | | |
|----------------------|------------------------|------------------------|
| Designed M. Demos | Checked D. Tuominen | Standards Approved |
|----------------------|------------------------|------------------------|

Std/Dwg No. **8-5 (2 of 3)**

320 Amp Approved Meter Bases

| Type | Usage | Amp Rating | Jaws | Manufacturer | Model Number | Notes |
|--------------|----------------------|------------|------|--------------------|---------------|---------------------------|
| Meter Socket | Overhead/Underground | 320 | 4 | Eaton B-Line | 324N | Hub cover, bypass |
| Meter Socket | Overhead/Underground | 320 | 4 | Eaton B-Line | 324N-SS | Hub cover, bypass |
| Meter Main | Underground | 320 | 4 | Eaton B-Line | HP40SHA | Bypass, lugs not included |
| Meter Main | Underground | 320 | 4 | Eaton B-Line | HP404040SHA | Bypass, lugs not included |
| Meter Socket | Overhead/Underground | 320 | 4 | Milbank | U3548-X | Hub cover, bypass |
| Meter Main | Underground | 320 | 4 | Milbank | M404-UG-LC-BS | Bypass |
| Meter Main | Underground | 320 | 4 | Schnieder Square D | SU3040D400CB | Bypass |

NOTES

- A. For underground service, a three-inch bottom knockout is recommended to accommodate Cowlitz PUD preferred 3" Schedule 40 PVC conduit and slip riser.
- B. All meter bases must be ring type and must be equipped with line-side mechanical lugs for Cowlitz PUD service connections.
- C. All meter bases must be rated NEMA 3R or better.
- D. All bypasses must be manual link type **only**.
- E. Customers may request approval for other meter bases meeting these requirements by contacting Cowlitz PUD Engineering Department.


STANDARDS



PUBLIC UTILITY DISTRICT NO. 1
 Cowlitz County, Washington
 961 12th Avenue
 Longview, Washington

**CONSTRUCTION STANDARDS
 ELECTRICAL SERVICE REQUIREMENTS
 APPROVED METER BASES**

| REV | DATE | DESCRIPTION |
|-----|----------|-----------------|
| 0 | 06/09/25 | Initial release |
| | | |
| | | |

| | | |
|----------------------|------------------------|---|
| Designed M. Demos | Checked D. Tuominen | Standards Approved  |
|----------------------|------------------------|---|

Std/Dwg No.
8-5 (3 of 3)