





NOTES

- A. Electrical inspection sticker (L & I) must be displayed on service equipment.
- B. Each grouped meter base and panel cover must have permanently engraved metal, hard plastic, or self-adhesive label with a minimum of 3/8" high letters to identify the unit service address. Permanent lettered or numbered addresses must be placed on each corresponding main door entrance before power is connected, if permanent door and siding has already been installed. Otherwise, clearly identified temporary lettering or numbers must identify each unit.
- C. Meters must be located in an easily accessible area approved by Cowlitz PUD, preferably outside. Indoor installations must be in an approved electrical room, see Standard 8-70 for details.
- D. House meter bases shall be provided with manual bypass provisions except where the meter serves lighting only, then no bypass is required.
- E. A safety socket is required on any three phase service, or any service 480V or above. All safety socket bypasses must be EUSERC 311/312 compliant.
- F. Meters facing a roadway or parking area must be at least 3' away from the curb or road edge. Protective bollards may also be required, as determined by Cowlitz PUD. See standard 7-86 for bollard installation details.
- G. All grounding and bonding shall be in accordance with NEC Article 250 & WAC 296-46B-250. Contact Washington State L&I for more information.
- H. For an occupied dwelling, an outdoor disconnect may be required per NEC 230.85. For multi-unit services with more than 6 meters, a single outdoor main disconnect is required per NEC 230.71. Contact Washington State L&I for more information.

STANDARDS  PUBLIC UTILITY DISTRICT NO. 1 <small>Cowlitz County, Washington 961 12th Avenue Longview, Washington</small>	CONSTRUCTION STANDARDS ELECTRICAL SERVICE REQUIREMENTS MULTI-UNIT UNDERGROUND SERVICE		<table border="1"> <thead> <tr> <th>REV</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>2/23/26</td> <td>Initial release</td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	REV	DATE	DESCRIPTION	0	2/23/26	Initial release						
	REV	DATE	DESCRIPTION												
0	2/23/26	Initial release													
<table border="1"> <tr> <td style="text-align: center;">Designed G. Reyes</td> <td style="text-align: center;">Checked M. Demos</td> <td style="text-align: center;">Standards Approved </td> <td style="text-align: center;">Std/Dwg No. 8-50</td> </tr> </table>	Designed G. Reyes	Checked M. Demos	Standards Approved 	Std/Dwg No. 8-50											
Designed G. Reyes	Checked M. Demos	Standards Approved 	Std/Dwg No. 8-50												